



ME-AGS wiring diagram –

For MQ Power (Whisperwatt Generators DAC-7000SS Diesel Generators)



Start Relay and Preheat Relay 2 = SPDT 65 Amp, 12 VDC coil relay;
 On Relay = DPDT 65 Amp, 12 coil relay; Preheat Relay 1 = RTE-P2 Timer made by IDEC.



* to enable Portable Mode, the ME-AGS must be revision 3.2 or higher

Magnum Energy, Inc. provides this diagram to assist in the installation of the Auto-Generator Start controller. Since the use of this diagram and the conditions or methods of installation, operation and use are beyond the control of Magnum Energy, Inc., we do not assume responsibility and expressly disclaim liability for loss, damage or expense arising out of the installation, operation and use of this unit.